

Annexure D

BUILDING SAFETY CERTIFICATE

No.

Dated : 06/02/2025

It is certified that the existing building **GD GOENKA PUBLIC SCHOOL** (name of the building or premises at **VILLAGE – KARAUNDA (BHAVALKEDA BLOCK) TEHSIL -SADAR**

SHAHJAHANPUR (address) is having block(s)/Floor(s) as per details below:

Detail of Block(s) in School	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	GROUND FLOOR + 2 UPPER FLOORS	NIL	NIL	NIL	NIL	NIL

The building is owned/occupied by **GD GOENKA PUBLIC SCHOOL** (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of **SURENDRA KUMAR (AE) & RAKESH KUMAR JE (PWD)** Name of Department/ UP Govt.) on **05/02/2025** (date of inspection) in the presence of **VINOD KUMAR GUPTA (CHAIRMAN), VINOD CHARITABLE FOUNDATION** **SHAHJAHANPUR** (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from **05/02/2025** for a period of **04/02/2026** year in accordance with rule and subject to compliance of the specific conditions as appended.

1. 6.00 mt. open area must be required around the building (N.B. Code Part -3 Clause 8.3.1 (a))
2. Provision of Earth quake Resistance drawing (as per Zone-III) Must be required.
3. Stair width of Building is not less than 1.50mt and rise 150mm. and Read 300mm must be required (NB Code Part-3 Clause 12.18)
4. Height of Parapet wall of building is not less than 1.00 mt and not above than 1.20mt (n.b Code Prt-3 Clause - 12.11)

Issued on **06/02/2025** at **4.00Pm** by

Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail

Assistant Engineer
P.D., P.W.D.
Signature with Seal : **Shahjahanpur**
Name: **Surendra Kumar**
Designation: **A.E.**

Name & Address of Department Office : **P.D.; P.W.D.; Shahjahanpur**